

REGISTRATION OF PLANT DESIGN FOR PRESSURE EQUIPMENT



Government of South Australia
SafeWork SA

Client No: 6063985 Printed Date: 12/10/2018

MCH AUSTRALIA PTY LTD
WAREHOUSE 2 33-35 SMITH ROAD
SPRINGVALE VIC 3171

Contact Details

ABN 50 560 588 327

Address: Level 4
33 Richmond Road,
KESWICK SA 5035
Postal: GPO BOX 465
ADELAIDE SA 5001
Phone: 1300 365 255
Email: licensing.safework@sa.gov.au
Website: safework.sa.gov.au

DETAILS OF REGISTERED DESIGN

Site address:

Design Registration Number: SD 20081074-1

Issued: 02 Dec 2008

Description: 2.6 KG CO2 GAS CYLINDER

Design Drawing Numbers: 002 Rev 4

Designer: KEE DOERY - MCH AUSTRALIA PTY LTD

Design Code: AS2030.1:1999, AS2875:1995

Design Criteria: DESIGN PRESSURE: 18.57 Mpa DESIGN TEMPERATURE: 0 deg C (MIN), 65 deg C (MAX)

Verifier Name: W TJIO - AML CONSULTANTS

This is to certify that the design of the item of plant described has been registered pursuant to the *Work Health and Safety Regulations 2012 (SA)* and the National Occupational Health and Safety Standard for Plant. If this registered design is altered, it must be re-submitted for re-registration within 21 days or this registration will lapse. The Registered design number must be provided to any manufacturer, importer or supplier of the plant. The Design Registration Number: SD 20081074-1 must be permanently marked on the plant. Non compliance with the regulations may incur a penalty.

Mr David Rynes,
Delegate for the Director
SafeWork SA